



HUB TESTING LABORATORY, INC.

Environmental Testing Service

95 Beaver Street - Waltham, MA 02453

(781) 893-8330 (781) 893-4414 (fax)

March 22, 2001

Report For: Mr. Ed Dufresne
LEA Designated person
Electrical Inspector's Office
City Hall
4 Summer Street
Haverhill, MA 01830-5877

Hub I.D.: 13246

Date Received: January 29, 2001

Project: John C. Tilton Elementary

Scope: This office was requested to collect bulk samples of materials that were previously identified as being a suspect asbestos containing material under the AHERA regulation. Additional samples were collected by this office to bring the total number of samples collected per homogeneous material to a minimum of three. The samples were returned to the laboratory for analysis.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.


Results: Homogeneous Material: Wallboard

Sample ID	Location	Composition	
13246-7-1	Room 005	Cellulose	95%
		Opagues	5%

The sample was received in good condition.

Comment: In most cases two samples were collected per homogeneous material since a single sample had been collected during the original AHERA inspection.

The samples collected were not asbestos containing materials. These homogeneous materials can be removed from the suspect materials list in the AHERA reports.



Susan Boyle
Vice President