

HUB TESTING LABORATORY, INC.

Environmental Testing Service

95 Beaver Street - Waltham, MA 02453

(781) 893-8330 (781) 893-4414 (fax)

April 30, 2002

Report For: Mr. Ed Dufresne
Haverhill Schools Designated Person
Electrical Inspector's Office
City Hall
4 Summer Street
Haverhill, MA 01830

Hub I.D.: 14330

Project: Consentino School

Date Samples Collected: April 24, 2002

Scope: Four samples of suspect material were collected by Hub Testing Laboratory. It was requested that the samples be analyzed for the presence of asbestos.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results:	<u>Sample I.D.</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	14330-1	Spray-on from beam	*Chrysotile	5
		Color: Beige	Mica	5
			Non-fibrous	90
	14330-2	Spray-on from beam	*Chrysotile	5
		Color: Beige	Mica	5
			Non-fibrous	90
	14330-3	Hard spray-on from duct	Non-fibrous	100
		Color: Off-white		


Results:	<u>Sample I.D.</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	14330-4	Spray-on from joist at tee end	*Chrysotile	10
		Color: Beige	Mica	5
			Non-fibrous	85

NVLAP 1150

*Chrysotile is a common form of asbestos.

Condition: The samples were received in good condition.

Comment: Samples 14330-1, 14330-2, and 14330-4 are asbestos containing materials. This analysis pertains only to the samples analyzed. This report shall not be reproduced except in full, without the written approval of the laboratory.


For Susan Boyle, Vice President
Hub Testing Laboratory