



HUB TESTING LABORATORY, INC.

Environmental Testing Service

95 Beaver Street - Waltham, MA 02453
(781) 893-8330 (781) 893-4414 (fax)

May 10, 2011

Report For: Haverhill Public Schools
Attn: Jeff Dill
4 Summer Street
Haverhill, MA 01830

Project Address: Consentino School
685 Washington Street
Haverhill, MA 01830

Hub I.D.: 21717

Date Collected: May 6, 2011

Discussion Hub Testing Laboratory was requested to verify the presence of asbestos in the stored laboratory table tops located in classroom 42 of the Consentino School. Two sizes of laboratory table tops were identified; one that was approximately 8 feet long by 3 feet wide and 16 that were approximately 10 feet long and 2 feet wide. The laboratory table tops were stored in groups of four along the front, back and right side of the classroom. The larger laboratory table top was resting on the group of four at the back of the classroom. The inspector examined each laboratory table top and determined them to be one homogenous material. A total of four samples were collected; three samples from the smaller laboratory table tops and one sample of the larger laboratory table top. These samples were returned to the laboratory and analyzed for the presence of asbestos.


Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results:	<u>Sample I.D.</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	21717-1	10' x 2' Laboratory table top	Cellulose	60
		Color: Dark Brown	Non-fibrous	40
	21717-2	10' x 2' Laboratory table top	Cellulose	60
		Color: Dark Brown	Non-fibrous	40
	21717-3	10' x 2' Laboratory table top	Cellulose	60
		Color: Dark Brown	Non-fibrous	40
	21717-4	8' x 3' Laboratory table top	Cellulose	60
		Color: Dark Brown	Non-fibrous	40

NVLAP 101150-0

Condition: The samples were received in good condition.

Comment: No asbestos was detected in the samples submitted. This analysis pertains only to the samples analyzed. This report shall not be reproduced except in full, without the written approval of the laboratory.



 Susan Boyle, Vice President
 Hub Testing Laboratory