

# HUB TESTING LABORATORY, INC.

## Environmental Testing Service

95 Beaver Street - Waltham, MA 02453  
(781) 893-8330 (781) 893-4414 (fax)

May 15, 2002

Report For: Mr. Ed Dufresne  
Haverhill Schools Designated Person  
Electrical Inspector's Office  
City Hall  
4 Summer Street  
Haverhill, MA 01830

Hub I.D.: 14372

Project: Consentino School

Date Collected: May 7, 2002

Scope: Three samples of suspect material were collected by Hub Testing Laboratory. It was requested that the samples be analyzed for the presence of asbestos.


Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results:	<u>Sample I.D.</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	14372-1	Spray-on Color: Beige	Non-fibrous	100
	14372-2	Spray-on Color: Beige	Non-fibrous	90
	14372-3	Ceiling tile Color: Off-white	Cellulose Mineral wool Non-fibrous	30 60 10

NVLAP 1150

Condition: The samples were received in good condition.

Comment: The samples submitted are not asbestos containing materials. This analysis pertains only to the samples analyzed. This report shall not be reproduced except in full, without the written approval of the laboratory.

  
Susan Boyle, Vice President  
Hub Testing Laboratory