



HUB TESTING LABORATORY, INC.

Environmental Testing Service

95 Beaver Street - Waltham, MA 02453
(781) 893-8330 (781) 893-4414 (fax)

August 22, 2001

Report For: Mr. Ed Dufresne
LEA Designated Person
Haverhill Public Schools
4 Summer Street
Haverhill, MA 01830-5877

Hub ID: 13793

Project: Constentino School


Scope: Hub Testing Laboratory was requested to collect a sample from the safe at the Constentino school. It was requested that the sample be analyzed for the presence of asbestos.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results:	<u>Sample ID</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	13793	Safe door insulation Color: White	Mineral Chip	100

All samples were received in good condition.

Comment: The sample is not an asbestos containing material. This report shall not be reproduced except in full, without the written approval of the laboratory.


Susan Boyle
Vice President
MA. Analytical
Lab #AA000013