

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

Roof Drain Insulation Fittings. TSI

Condition: Damaged – There is visible damage to the fittings from repeated ball strikes in the gymnasium.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	ADD FITTINGS IN CLASSROOMS ABOVE LOCKER ROOMS.	
New 3-Year Reinspection			

Ceiling Plaster. Surfacing Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	NON-ASBESTOS	SEE HOMOGENEOUS AREA SHEET
New 3-Year Reinspection			

Canvas Covered Duct Insulation. TSI

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	ADD - ABOVE GIRLS LOCKER ROOMS	
*sampled 2101 and found to not contain asbestos			
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

Composition Panels, 3' x 6'. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>Jim Bell</i>	None	NA
New 3-Year Reinspection			

Ceiling Tile, 1' x 1'. Miscellaneous Material.

Condition: Damaged – There is damage to ceiling tile due to water, abuse and maintenance throughout.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>Jim Bell</i>	NON-ASBESTOS. See HOMOGENEOUS AREA SHEET	
New 3-Year Reinspection			

Ceiling Tile, 2' x 4'. Miscellaneous Material.

Condition: Damaged – There is damage to ceiling tile due to water, abuse and maintenance throughout.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

Tan Fibrous Insulation, "Weil-McLain" Boiler. TSI.

Condition: Damaged – There is visible damage to the under side of the insulation jacket.
There is visible insulation debris on the boiler support pad.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	None	N/A
New 3-Year Reinspection			

Plaster Overspray. Surfacing Material.

Condition: Inspector could not locate material.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	None	N/A
2-20-01	<i>J. Bell</i>	sampled 2/01 and found to not contain asbestos	
New 3-Year Reinspection			

Roof Material. Miscellaneous Material

Condition: This material is fiberglass.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	None - Asbestos	
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

“Sheetrock” Wall Partitions. Miscellaneous Material.

Condition: Damaged. There is some damage from abuse on $\approx 20\%$ of the partitions.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
* sampled 2/01 and found to not contain asbestos			
New 3-Year Reinspection			

4” Cove, Brown. Miscellaneous Material.

Condition: Damaged. There is significant damage to the brown cove base throughout $\approx 70\%$ of the school.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	J. B. Bell	None	N/A
New 3-Year Reinspection			

4” Cove, Brown Mastic. Miscellaneous Material.

Condition: Damaged. There is significant damage to the brown cove base throughout $\approx 70\%$ of the school. The cove mastic is attached to the cove base and should be considered one material.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	J. B. Bell	None	N/A
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

4" Cove, White. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	NONE	N/A
New 3-Year Reinspection			

4" x 6" Ceramic Wall Tile Grout. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	NONE	N/A
New 3-Year Reinspection			

2" Green Ceramic Wall Tile Grout. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>J. Bell</i>	NONE	N/A
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

1' x 3' Black Window Sills. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01		NONE	NA
New 3-Year Reinspection			

Off White Pull Down Window Shades. Miscellaneous Material.

Condition: Damage. There is some small tears and fraying at edges of shades.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
* sampled 2/01 and found to not contain asbestos			
New 3-Year Reinspection			

Black Sink Insulation. Surfacing Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01		NONE	NA
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

2' x 3' White Custodial Sinks. Miscellaneous Material.

Condition: Damaged. There is damage to the leading edge of the white floor sinks in the custodial closets.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>Susan Boyle</i>	None	
New 3-Year Reinspection			

Carpet Mastic. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>Susan Boyle</i>	None	
New 3-Year Reinspection			

1' x 4' Brown/Black Kick Plates on double door bases. Miscellaneous Material.

Condition: Damaged. There is damage to the kick plates from normal usage.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>Susan Boyle</i>	None	
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

Various 4' x 16' Chalk Boards. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>[Signature]</i>	None	
New 3-Year Reinspection			

Various 4' x 8' Chalk Boards. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>[Signature]</i>	None	
New 3-Year Reinspection			

Plaster, Grey in the Administration office. Miscellaneous Material.

Condition: Damaged. There is significant damage to the plaster within the vault door. It is assumed that the plaster throughout the vault is in similar condition.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>[Signature]</i>	NONE	N/A
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

3' x 8' Divider Panels. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
New 3-Year Reinspection			

4' x 16' Divider Panels. Miscellaneous Material.

Condition: Damaged. There is visible damage to panels from abuse.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2/20/01	<i>[Signature]</i>	None	N/A
New 3-Year Reinspection			

2' x 12' White Ceiling Panels. Miscellaneous Material.

Condition: Not Damaged.


1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01	<i>[Signature]</i>	None	
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL


Gray Outdoor Caulking. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01		NONE	N/A
New 3-Year Reinspection			


Black Outdoor Caulking. Miscellaneous Material.

Condition: Not Damaged.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01		NONE	N/A
New 3-Year Reinspection			

Canvas Curtain, Tan. Miscellaneous Material.

Condition: Not Damaged.


1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-01		DAMAGED	
New 3-Year Reinspection			

CONDITION OF HOMOGENEOUS AREA SUSPECT MATERIAL cont.

HOMOGENEOUS MATERIAL

Black Table/Lab Tops. Miscellaneous Material.

Condition: Damaged. There is significant damage to top surfaces from abuse.

1 st surveillance Date	Signature	Change in condition	Notified Designated Person
2-20-07		None	N/A
New 3-Year Reinspection			