

HUB TESTING LABORATORY, INC.

Environmental Testing Service

95 Beaver Street - Waltham, MA 02453
(781) 893-8330 (781) 893-4414 (fax)

March 22, 2001

Report For: Mr. Ed Dufresne
LEA's Designated Person
Haverhill Public Schools
4 Summer Street
Haverhill, MA 01830-5877

Hub ID: 13246

Date Received: January 29, 2001

Project: Walnut Square School

Scope: This office was requested to collect bulk samples of materials that were previously identified as being suspect asbestos containing materials under the AHERA regulation. Additional samples were collected by this office to bring the total number of samples collected per homogeneous material to a minimum of three. The samples were returned to the laboratory for analysis.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results: Homogeneous Material: Blown In Insulation
Visually identified as fiberglass.

Homogeneous Material: Paper Barrier Beneath Blown In
Insulation

Sample ID	Location	Fibrous Composition
13246-8-1	Attic, at access	Cellulose 85% Glass Fiber <1% Synthetic <1%
13246-8-2	Attic, at access	Cellulose 85% Glass Fiber <1% Synthetic <1%
13246-8-3	Attic, at access	Cellulose 85% Glass Fiber <1% Synthetic <1%


Homogeneous Material: Wall Plaster

Sample ID	Location	Fibrous Composition
13246-8-6	4A, First Floor	Animal Hair <1%

The samples were received in good condition.

Comment: In most cases two samples were collected per homogeneous material since a single sample had been collected during the original AHERA inspection.

The samples collected were not asbestos containing materials. These homogeneous materials can be removed from the suspect materials list in the AHERA reports.


Susan Boyle
Vice President