



# HUB TESTING LABORATORY, INC.

## Environmental Testing Service

95 Beaver Street - Waltham, MA 02453  
(781) 893-8330 (781) 893-4414 (fax)

April 9, 2001

Report For: Mr. Ed Dufresne  
LEA Designated Person  
Haverhill Public Schools  
4 Summer Street  
Haverhill, MA 01830-5877

Hub ID: 13376

Project: Walnut Square School

Scope: Hub Testing Laboratory collected one sample from the Walnut Square school. It was requested that the sample be analyzed for the presence of asbestos.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results:	<u>Sample ID</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	13376-3A	Insulation from breaching Color: blue	Non fibrous Synthetic Material	70 30
	13376-3B	Cover from breaching Color: white	Fiberglass Non fibrous	95 5

All samples were received in good condition.

Comment: The sample is not an asbestos containing material. This report shall not be reproduced except in full, without the written approval of the laboratory.

Susan Boyle  
Vice President  
MA Analytical  
Lab #AA000013