



HUB TESTING LABORATORY, INC.

Environmental Testing Service

95 Beaver Street - Waltham, MA 02453
(781) 893-8330 (781) 893-4414 (fax)

March 23, 2001

Report For: Mr. Ed Dufresne
LEA Designated Person
Haverhill Public Schools
4 Summer Street
Haverhill, MA 01830-5877

Hub Id: 13327

Project: Whittier School, Room 9

Scope: Hub Testing Laboratory collected three samples of floor tile and mastic. It was requested that the samples be analyzed for the presence of asbestos.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.


Results:	<u>Sample ID</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	13327-1A	9x9" floor tile Color: tan	*Chrysotile Non-fibrous	8 92
	13327-1B	Mastic on floor tile Color: black	Non-fibrous	100
	13327-2A	9x9" floor tile Color: tan	*Chrysotile Non-fibrous	8 92
	13327-2B	Mastic on floor tile Color: black	Non-fibrous	100
	13327-3A	9x9" floor tile Color: tan	*Chrysotile Non-fibrous	8 92
	13327-3B	Mastic on floor tile Color: black	Non-fibrous	100

All samples were received in good condition.

* Chrysotile is a common form of asbestos.

Comment:

The tan floor tile samples from Room 9 (13327-1A, 13327-2A, 13327-3A) are asbestos containing materials. The mastic samples do not contain asbestos. This analysis pertains only to the samples analyzed. This report shall not be reproduced except in full, without the written approval of the laboratory.



Susan Boyle
Vice President
MA Analytical
Lab # AA000013