



HUB TESTING LABORATORY, INC.
Environmental Testing Service

95 Beaver Street - Waltham, MA 02453
(781) 893-8330 (781) 893-4414 (fax)

April 9, 2001

Report For: Mr. Ed Dufresne
LEA Designated Person
Haverhill Public Schools
4 Summer Street
Haverhill, MA 01830-5877

Hub ID: 13376

Project: Whittier School

Scope: Hub Testing Laboratory collected three samples from the Whittier school. It was requested that the samples be analyzed for the presence of asbestos.

Analysis: Analysis for the presence of asbestos was performed using Polarized Light Microscopy EPA/600/R-93/116, July 1993.

Results:	<u>Sample ID</u>	<u>Material/Location</u>	<u>Composition</u>	<u>%</u>
	13376-4	Vibration dampener Color: tan	Cellulose Non-fibrous	80 20
	13376-5	Vibration dampener Color: brown	Cellulose Non-fibrous	80 20
	13376-6	Vibration dampener Color: brown	Cellulose Non-fibrous	90 10

All samples were received in good condition.

Comment: The samples are not asbestos containing materials. This report shall not be reproduced except in full, without the written approval of the laboratory.

Susan Boyle
Vice President
MA Analytical
Lab #AA000013